



To

The Principal,
St. Vivekanand Lotus Valley. Public School,
Jagadhri District Yamunanagar.

Memo No. 551

Dated: 16/05/2024

Subj.: Issuance of School Building Safety Certificate.

Ref.: Your office letter No. SVLVPS/24/ dated 07.05.2024.

In this connection, it is intimated that the building of St. Vivekanand Lotus Valley. Public School Jagadhri District Yamuna Nagar has been inspected by Sub Divisional Engineer, Provincial Sub Division No. II, PWD B&R Branch Yamuna Nagar along with concerned JE and has reported that upon visual/physical inspection, the building apparently seems to be safe as no crack/ settlement has been observed during the inspection. However as for as seismic factor and structural safety of the building is concerned, the advice/opinion of the structural consultant may be sought. This certificate is valid for one year only.

This is for your information and necessary action please.

DA/Nil

Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br.,
Yamuna Nagar

Endst No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division PWD B&R Br., No. II Yamuna Nagar for information w.r.t. his office letter No. 144 dated 15.05.2024.

D. A. /Nil

Sd/-
Executive Engineer,
Jag. Provl. Divn. PWD B&R Br.,
Yamuna Nagar