



To

The Principal,
St. Vivekanand Lotus Valley Public School,
Adj-Sec-18, Huda Jagadhri,

Memo No. 2536

Dated: 1-8-25


Subj:- Submission of Application for Renewal Building Safety Certificate.

Ref:- Your office letter Memo No. 15 dated 15.07.2025.

In this connection, it is intimated that the building of St. Vivekanand Lotus Valley Public School, Adjoining Sec-18, Huda in Jagadhri has been inspected by Sub Divisional Engineer, Provincial Sub Division No. II PWD B&R Br., Yamuna Nagar along with concerned JE and has reported that no crack/settlement has been observed in the building. This department does not certify regarding safety from earthquake for the building which has already been constructed, therefore as for as seismic factor and structural safety of the building cited as subject is concerned, the advice/opinion of the structural consultant may be sought. This certificate is valid for one year only.

This is for your information and necessary action please.

DA/Nil



Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br.
Yamuna Nagar

Endst No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. II PWD B&R Br., Yamuna Nagar for information w.r.t. his office letter Memo No. 491 dated 22.07.2025.

DA/Nil


Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br.
Yamuna Nagar.